

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 69

Dated: 30-07-2026

It is certified that an inspection team headed by F.S. Joshi Incharge DWTL DMT

(Name of Officers with designation) from Dhamtari PHED

inspected the Mennonite English Senior Secondary School Dhamtari

(Name & Address of the school) on 28/07/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. dated 29/07/2026

of (NABL) Dhamtari (C.G.) (PHED Lab) certified that the

Mennonite English Senior Secondary School DMT (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till


Authorised Signatory
Distt. Water Testing Laboratory
Public Health Engg. Dept.

Signature with Seal: 
Name: **Assistant Engineer**
Designation: **Public Health Engg. Sub. Division**
Name & Address of the Office / Department: **Dhamtari (C.G.)**

To **Div. Dhamtari (C.G.)**
Mennonite English Senior
Secondary School Dhamtari
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



TC-1486

District Water Testing Laboratory
Public Health Engineering Department, Division Dhamtari Chhattisgarh
 Rudri Road Gokulpur Ward
 E-Mail-ec-phc-cg@nic.in Phone-07722-238719
Test Report

Kind of Sample- Drinking Water	Report No.DL/PHED/DMT	ULR- TC148602600000113F	Sample Collected By -	School Staff
Sender Name and Address :	Sender letter no.,	29	Sender's Letter Date	28.07.2026
Principal And Mennonite English Sr.Sec. School Dhamtari (C.G.)	Date Of Collection	28.07.2026	Sampling plan & Procedure No.	Not Done By Lab
	DL Receipt No.	69	DL Receipt Date	28.07.2026
	Date Of Analysis Started	28.07.2026	Date of Analysis Completed	29.07.2026
No.	DISTRICT	BLOC K	Location/Source	Sample ID
1	Dhamtari	Dhamtari	Mennonite English Sr.Sec. School Dhamtari	874

Details of parameters, their test methods, unit and specification as per IS/APHA

No.	Characteristics	Test Method IS 3025		Unit of Measurement	As Per IS-10500:2012 for Drinking Water		Results				
		3	4		Acceptable Limit	Permissible Limit	1	2	3	4	5
1	2	3	4	5	6	7	8				
1	Color	IS 3025	Part -04	Hazen	5-15	No Relaxation	7	-	-	-	-
2	Odour	IS 3025	Part -05	-	Agreeble	Agreeble	Agreeble	-	-	-	-
3	Taste	IS 3025	Part -08	-	Agreeble	Agreeble	Agreeble	-	-	-	-
4	Turbidity	IS:3025	Part-10	NTU	1.0	5.0	0.1	-	-	-	-
5	Chloride as cl-	IS:3025	Part-32	mg/L	250	1000	64.95	-	-	-	-
6	TDS	IS:3025	Part-16	mg/L	500	2000	290	-	-	-	-
7	Total Alkalinity as CaCO3	IS:3025	Part - 23	mg/L	200	600	47.61	-	-	-	-
8	Calcium as Ca++	IS:3025	Part - 40	mg/L	75	200	57.25	-	-	-	-
9	Magnesium as mg++	IS:3025	Part - 46	mg/L	30	100	15.18	-	-	-	-
10	pH	IS: 3025	Part - 11	pH Scale	6.5-8.5	No Relaxation	6.7	-	-	-	-
11	Total Hardness as CaCO3	IS:3025	Part - 21	mg/L	200	600	205.63	-	-	-	-

1. The report should not be produced partly or full without approval of singntory authority of legal purposes.
 2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolented in the absance of an alternative source but upto the limits indicated under the "permissible limit In the absance of alternate source" In column 7 above wh ich the sources will have to be rejected.
 3. The results refer only to tested samples and paramater tested.
 4. samples will be stored for a period of 10 days from date of Issue of report.
 5. This lab does not hold any responsiblilty for variation In results for samples kept on hold for want of clarification.
 6. The Laboratory does not hold any responsibility for variation in results for samples kept on hold for want of clarification.

Issue No... 113.../DL/Date 29-07-26
 Page No 01 to 01



(Signature)

F.S.Joshi
 Chemist
 Authorised Signatory
 District Water Testing Laboratory
 PHED Dhamtari (C.G.)

District Water Testing Laboratory
Public Health Engineering Department, Division Dhamtari Chhattisgarh
 Rudri Road Gokulpur Ward
 E-Mail-cc: phe-cg@nic.in Phone-07722-238719
Test Report

Kind of Sample- Drinking Water		Report No.DL/PHED/DMT		ULR- TC148602600000113F		Sample Collected By -		School Staff		
Sender Name and Address :		Sender letter no.		29		Sender's Letter Date		28.07.2026		
Principal And Menonite English Sr.Sec. School Dhamtari (C.G.)		Date Of Collection		28.07.2026		Sampling plan & Procedure No.		Not Done By Lab		
		DL Receipt No.		69		DL Receipt Date		28.07.2026		
		Date Of Analysis Started		28.07.2026		Date of Analysis Completed		29.07.2026		
No.	DISTRICT	BLOC K		VILLAGE		Location/Source		Sample ID		
1	Dhamtari	Dhamtari		Dhamtari		Menonite English Sr.Sec. School Dhamtari		874		
No.	Characteristics	Test Method IS 3025	Unit of Measurement	As Per IS-10500:2012 for Drinking Water		Results				
				Acceptable Limit	Permissible Limit	1	2	3	4	5
1	Iron as Fe++	IS:3025	3500-Fe -B	mg/L	0.3	1.0	NA	-	-	-
2	Nitrate as NO3++	APHA 23rd ed	4500-NOJ - B	mg/L	45	45	NA	-	-	-
3	Fluoride as F	APHA 23rd ed	4500-F-C	mg/L	1.0	1.5	NA	-	-	-
4	Sulphates as SO42-	IS:3025	Part - 24	m&fl	200	400	NA	-	-	-
5	Residual Chlorine	APHA 23rd ed	Part - 26	mg/L	0.2	1	NA	-	-	-
6	Specific Conductivity	IS:3025	Part - 14	µS/cm	500	2000	NA	-	-	-
7	Total Coliform per 100 ml	24 Hrs			Nil	Nil	Nil	-	-	-

1. The report should not be produced partly or full without approval of singnatory-authority of legal purposes.

2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source" In column 7 above which the sources will have to be rejected.

3. The results refer only to tested samples and parameter tested.

4. samples will be stored for a period of 10 days from date of Issue of report.

5. This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.

6. The Laboratory does not hold any responsibility for variation in results for samples kept on hold for want of clarification.

Issue No. 113/DL/Date 29-07-26
 Page No 01 to 01




F.S. Joshi
 Chemist
 Authorised Signatory
 District Water Testing Laboratory
 PHED Dhamtari (C.G.)